English Cymraeg

Energy performance certificate (EPC)

31 Trevelyan Street LIVERPOOL L9 1EL	Energy rating	Valid until:	31 May 2032
		Certificate number:	2521-7598-3318-3121-5812
Property type	Λ	/lid-terrace hc	buse
Total floor area	75 square metres		

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is C. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

https://find-energy-certificate.service.gov.uk/energy-certificate/2521-7598-3318-3121-5812

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, 270 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Air source heat pump, radiators, electric	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO2. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Air source heat pump
- Solar photovoltaics

Primary energy use

The primary energy use for this property per year is 116 kilowatt hours per square metre (kWh/m2).

About primary energy use

How this affects your energy bills

An average household would need to spend £1,073 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £285 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 8,885 kWh per year for heating
- 2,749 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces

6 tonnes of CO2

This property produces

This property's potential production

1.5 tonnes of CO2

0.7 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Do I need to follow these steps in order?

Step 1: Internal or external wall insulation

Typical installation cost	£4,000 - £14,000
Typical yearly saving	£152
Potential rating after completing step 1	79 C

Step 2: Floor insulation (suspended floor)

Typical installation cost	£800 - £1,200
Typical yearly saving	£45
Potential rating after completing steps 1 and 2	80 C

Step 3: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£88
Potential rating after completing steps 1 to 3	83 B

Advice on making energy saving improvements

Get detailed recommendations and cost estimates

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joseph Clayton
Telephone	07493422231
Email	joe@nextenergyuk.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK304568

Telephone	0333 123 1418
Email	info@ecmk.co.uk

About this assessment

Assessor's declaration	Relative of homeowner or of occupier of the property
Date of assessment	31 May 2022
Date of certificate	1 June 2022
Type of assessment	► <u>RdSAP</u>

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>mhclg.digital-services@communities.gov.uk</u> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	0434-2884-7288-9525-4541 (/energy-certificate/0434-2884- 7288-9525-4541)
Valid until	23 August 2025
Certificate number	0434-2884-7288-9525-5575 (/energy-certificate/0434-2884- 7288-9525-5575)
Valid until	23 August 2025

<u>Help (/help)</u> <u>Accessibility (/accessibility-statement)</u> <u>Cookies (/cookies)</u> Give feedback (https://forms.office.com/e/KX25htGMX5) Service performance (/service-performance)

OGL

All content is available under the <u>Open Government Licence v3.0</u> (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



ht (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framewor